



CONNECTION LAYOUT FOR ALLOTMENTS < 8m WIDE

NOT TO SCALE



DETAIL A

SINGLE WATER CONNECTION LAYOUT FOR ALLOTMENTS < 8m WIDE



DETAIL B ALTERNATIVE

DUAL WATER CONNECTION LAYOUT FOR ALLOTMENTS < 8m WIDE

NOTES:

- REFER 4005-30002-01 & 4005-30002-02 FOR GENERAL NOTES.
- LOCATION OF CONNECTIONS:
WATER CONNECTIONS - DRINKING WATER AND NON DRINKING WATER:
 - STANDARD 'DEFAULT' POSITIONS ARE AS SHOWN.
 - ALTERNATIVE POSITIONS MAY BE SPECIFIED ON THE DESIGN DRAWING. APPROVAL OF THE SA WATER REPRESENTATIVE IS REQUIRED FOR THIS OPTION.
- NON DRINKING WATER PIPE & METER CONNECTION SHALL BE POSITIONED TO THE LEFT OF DRINKING WATER CONNECTION WHEN VIEWED FROM ROADWAY.
- FOR DUAL RETICULATION SYSTEMS (DRINKING WATER & NON DRINKING WATER) THE LOCATIONS AND CLEARANCES SHOWN ON THIS DRAWING SHALL BE ADHERED TO REGARDLESS OF WHETHER THE NON DRINKING WATER SYSTEM SCHEME IS SA WATER OR PRIVATELY OPERATED.
- WATER METERS ARE SHOWN IN A SA WATER APPROVED METER BOX.
HOWEVER, THE ABOVE GROUND METER LOCATION IS THE PREFERRED ALTERNATIVE. REFER 4005-30004-02 FOR DETAILS.
- SEWER CONNECTIONS:
 - FOR STANDARD POSITIONS REFER SEWER CONSTRUCTION MANUAL, SECTION 6.
 - OBSTRUCTIONS OR EXISTING DRAINS MAY REQUIRE AN ALTERNATIVE LOCATION.
 - SINGLE CONNECTIONS SHALL BE USED. SHOULD THE DESIGNER CONSIDER THE USE OF A 'Y' CONNECTION TO SERVE ADJOINING ALLOTMENTS, DETAILS FOR THIS OPTION SHALL BE PROVIDED TO SA WATER REPRESENTATIVE FOR APPROVAL.
 - SINGLE CONNECTIONS SHALL BE ON LOW SIDE OF ALLOTMENT UNLESS IT IS IMPRACTICAL.
- ALL DIMENSIONS IN MILLIMETRES.

REVISION PANEL					DESIGN PANEL			 SA Water Government of South Australia	SA WATER STANDARD DRAWINGS			A3	1
REV	DATE	DRN	DETAILS	APR	CURRENT REV	DESIGNED:	AUTHORISED:		WATER SUPPLY CONSTRUCTION MANUAL			SHT SIZE	REVISION
					AUTHORISED:	28/09/15	31/03/16	ALLOCATION OF SPACE			TOTAL SHEETS:		
					SIGNATURE:	RJP	T.GALEK	FOR SERVICES IN LAND DIVISIONS			SUPERSEDES: D4, D5		
						DRAWN:		ALLOTMENT FRONTAGE LESS THAN 8m			DRAWING NUMBER		
						MS					4005-30004-03		
1	31/03/16	MS	2016 STANDARDS REVIEW	TG		REVIEWED:					PREFIX	NUMBER	
						TG						SHEET	