



DETAIL A
PE FITTINGS FOR END CAP

NOTES:

- REFER 4005-30002-01 AND 4005-30002-02 FOR GENERAL NOTES.
- THE **PREFERRED METHOD FOR DISCONNECTION IS DISCONNECTION AT THE MAIN.**
APPROVAL OF THE SA WATER REPRESENTATIVE IS REQUIRED FOR DISCONNECTION AT THE KERB.
- FOR DISCONNECTION AT THE MAIN:
 - IF MAIN COCK INSTALLED:
 - TURN OFF,
 - DISCONNECT INSULATING ADAPTOR/ TAPPING NIPPLE,
 - IF TAPPING NIPPLE INSTALLED:
 - LEAVE SHORT LENGTH OF EXISTING PIPE - APPROX. 300,
 - FIT PE FITTINGS TO ACHIEVE PIPE END,
 - REFER DETAIL A FOR REQUIRED FITTINGS.
- FOR DISCONNECTION BEHIND KERB:
 - FITTINGS DEPENDENT UPON PIPE TYPE,
 - INSTALL AS SHOWN, REFER DETAIL A,
 - FIX ID TAG ON KERB FOR FUTURE CONFIRMATION OF DISCONNECTION LOCATION.
- FOR ALL DISCONNECTIONS, **INLET RISER, METER, OUTLET RISER SHALL BE REMOVED.**
- WHERE TEMPORARY REMOVAL OF METER REQUIRED, FIT HEX DR BRASS PLUG (BSP TAPERED THREAD) AND REMOVE METER AND OUTLET RISER.

REVISION PANEL					DESIGN PANEL		<div><div></div><div><div>This drawing is the property of the SOUTH AUSTRALIAN WATER CORPORATION and shall not be copied or modified in part or in whole without authorization.</div></div></div>		SA WATER STANDARD DRAWINGS WATER SUPPLY CONSTRUCTION MANUAL WATER CONNECTIONS DISCONNECTIONS PERMANENT & TEMPORARY			A3 SHT SIZE	1 REVISION
REV	DATE	DRN	DETAILS	APR	CURRENT REV	DESIGNED: 28/09/15	AUTHORISED: 31/03/16			TOTAL SHEETS:			
					AUTHORISED:	RJP	T.GALEK			SUPERSEDES: L3, L4			
					SIGNATURE:	DRAWN: 16/11/15	SIGNATURE:			DRAWING NUMBER			
						MS				4005-30010-03			
						REVIEWED: 21/03/16				PREFIX	NUMBER	SHEET	
-	31/03/16	MS	2016 STANDARDS REVIEW	TG		TG							