



PLAN

TABLE 1

No.	AS CONSTRUCTED DRAWING INFORMATION
1.	ADDRESS
2.	METER SIZE
3.	METER TYPE
4.	METER NUMBER
5.	ORIGINAL WATER CONNECTION PIPE DIAMETER
6.	ORIGINAL WATER CONNECTION PIPE MATERIAL TYPE
7.	WATER METER RELOCATED LEFT OR RIGHT
8.	LOCATION OF EXISTING INLET RISER - DISTANCE 'A'
9.	LOCATION OF RELOCATED INLET RISER - DISTANCE 'B'
10.	NEW PIPEWORK INSIDE / OUTSIDE FRONT BOUNDARY
11.	DISTANCE FROM FRONT BOUNDARY
12.	DEPTH OF NEW PIPEWORK

NOTES:

- REFER 4005-30002-01 AND 4005-30002-02 FOR GENERAL NOTES.
- CONNECTION (& METER) RELOCATION IS ONLY APPROVED FOR DN20 AND DN25 WATER METERS.  
**NO RELOCATION OF DN40 & DN50 METERS PERMITTED.**
- RELOCATION IS APPROVED FOR BOTH DRINKING WATER AND NON-DRINKING WATER SYSTEMS.
- THE OD25 PE PIPEWORK SHALL BE LAID IN FOOTPATH. SHOULD OTHER UTILITIES IMPACT COMPLIANCE WITH THIS REQUIREMENT, APPROVAL OF THE SA WATER REPRESENTATIVE SHALL BE SOUGHT FOR PERMISSION TO LOCATE PIPEWORK WITHIN THE PROPERTY (MAX 500 FROM FRONTAGE) OR WITHIN THE ROAD.
- DETECTABLE UNDERGROUND WARNING TAPE SHALL BE LAID APPROX 150 ABOVE OD25 PE PIPE. TAPE MARKINGS WILL BE DEPENDENT UPON THE DRINKING WATER SYSTEM.
- RELOCATION OF THE WATER CONNECTION OR WATER METER IS PERMITTED ONCE. A RELOCATED CONNECTION OR METER CANNOT BE MOVED.
- REFER 4005-30002-01 FOR GENERAL NOTES.
- REFER 4005-30006-01 FOR WATER CONNECTION NOTES & REQUIREMENTS.
- REFER 4005-30008-01 FOR FOR DN20 AND DN25 WATER METERS ASSEMBLY.
- FOR ALL RELOCATIONS:  
THE CONTRACTOR SHALL PROVIDE THE SA WATER WITH AN 'AS CONSTRUCTED' DRAWING WITH REQUIRED DIMENSIONS & INFORMATION LISTED IN TABLE 1.
- ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

REVISION PANEL					DESIGN PANEL		 This drawing is the property of the  SOUTH AUSTRALIAN WATER CORPORATION and shall not be copied or modified in part or in whole without authorization.	SA WATER STANDARD DRAWINGS WATER SUPPLY CONSTRUCTION MANUAL WATER CONNECTION RELOCATION/ WATER METER RELOCATION (DN20 & DN25 ONLY)		A3 SHT SIZE		1 REVISION	
REV	DATE	DRN	DETAILS	APR	CURRENT REV AUTHORISED:	DESIGNED: 28/09/15 RJP		AUTHORISED: 31/03/16 T.GALEK	TOTAL SHEETS:				
					SIGNATURE:	DRAWN: 16/11/15 MS		SIGNATURE:	SUPERSEDES: K7, L6				
						REVIEWED: 21/03/16 TG			DRAWING NUMBER				
1	31/03/16	MS	2016 STANDARDS REVIEW	TG		4005-30010-05							
								PREFIX	NUMBER	SHEET			