


#### NOTES:

1. REFER 4005-20002-01 TO 4005-20002-03 FOR GENERAL NOTES.
2. REFER 4005-20006-03 FOR TYPICAL SEWER CONNECTION DETAILS.
3. DURING COMPACTION OF THE CONCRETE BLOCK, THE COVER & FRAME SHALL BE REMOVED. THE CONTRACTOR SHALL ENSURE THE BLOCK DOES NOT MOVE TO IMPEDE FUTURE ACCESS TO THE THREADED CAP.
4. REFER SECTION 6 FOR MORE ALTERNATIVES TO THE STANDARD CONNECTION ASSEMBLY.
5. ALL DIMENSIONS IN MILLIMETRES.

INSPECTION POINT DEPTH TABLE		
CATEGORY	MIN	MAX
RESIDENTIAL	1400	2600
INDUSTRIAL / COMMERCIAL	1400	3500

REVISION PANEL					DESIGN PANEL		 <p>SA Water</p> <p>This drawing is the property of the SOUTH AUSTRALIAN WATER CORPORATION and shall not be copied or modified in part or in whole without authorization.</p>	SA WATER STANDARD DRAWINGS SEWER CONSTRUCTION MANUAL INSPECTION POINT TYPICAL DETAILS		A3	1
REV	DATE	DRN	DETAILS	APR	CURRENT REV	AUTHORISED:				SHT SIZE	REVISION
						03/08/15					
						31/03/16					
1	31/03/16	MS	2016 STANDARDS REVIEW	TG							

TOTAL SHEETS:		
SUPERSEDES: 94-0164-02 (K2)		
DRAWING NUMBER		
4005-20006-02		
PREFIX	NUMBER	SHEET