

	Minimum	Maximum	Average	Units	ADWG Health Guidelines	ADWG Aesthetic Guidelines	Compliance (%)	
							Health	Aesthetic
System: Indulkana								
Alkalinity as Calcium Carbonate	106	119	113	mg/L				
Bicarbonate	129	145	137	mg/L				
Calcium	34.7	38.3	36.5	mg/L				
Carbonate	0	0	0	mg/L				
E.coli	0	0	0	MPN/100mL	0 - 0		100.00	
Fluoride	<0.1	<0.1	<0.1	mg/L	0 - 1.5		100.00	
Iron - Total	0.0046	0.0246	0.0146	mg/L		0 - 0.3		100.00
Magnesium	0.49	0.64	0.57	mg/L				
Manganese - Total	0.0003	0.0012	0.0008	mg/L		0 - 0.1		100.00
				mg/L	0 - 0.5		100.00	
pH	7.8	8.0	7.9	pH units		6.5 - 8.5		100.00
Sodium	9.1	9.3	9.2	mg/L		0 - 180		100.00
Total Dissolved Solids (by EC)	140	140	140	mg/L		0 - 600		100.00
Total Hardness as CaCO3	89	98	94	mg/L		0 - 200		100.00
Zinc - Total	0.1122	0.3684	0.2403	mg/L		0 - 3		100.00

Australian Drinking Water Guidelines - 2011

Although we aim for 100% compliance, the ADWG Recognises that occasional exceedances may occur. Where there are sufficient sample results from a 12 month period, the 95th percentile statistic should be used to determine performance against the guideline value. Any exceedance requires immediate investigation and corrective action as agreed with SA Health.

Disclaimer: While every effort has been made to ensure the accuracy of the above data, SA Water accepts no liability for and gives no undertakings, guarantees or warranties concerning the use of the data for any purposes.